

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/020/26	Model No.: KFARQ-6-90%	Date: 17-01-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 020/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 01901 To 2000 And 1905A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1905A and removed from the Lot/Batch							
1901	Pass	1902	Pass	1903	Pass	1904	Pass
1905	Pass	1906	Pass	1907	Pass	1908	Pass
1909	Pass	1910	Pass	1911	Pass	1912	Pass
1913	Pass	1914	Pass	1915	Pass	1916	Pass
1917	Pass	1918	Pass	1919	Pass	1920	Pass
1921	Pass	1922	Pass	1923	Pass	1924	Pass
1925	Pass	1926	Pass	1927	Pass	1928	Pass
1929	Pass	1930	Pass	1931	Pass	1932	Pass
1933	Pass	1934	Pass	1935	Pass	1936	Pass
1937	Pass	1938	Pass	1939	Pass	1940	Pass
1941	Pass	1942	Pass	1943	Pass	1944	Pass
1945	Pass	1946	Pass	1947	Pass	1948	Pass
1949	Pass	1950	Pass	1951	Pass	1952	Pass
1953	Pass	1954	Pass	1955	Pass	1956	Pass
1957	Pass	1958	Pass	1959	Pass	1960	Pass
1961	Pass	1962	Pass	1963	Pass	1964	Pass
1965	Pass	1966	Pass	1967	Pass	1968	Pass
1969	Pass	1970	Pass	1971	Pass	1972	Pass
1973	Pass	1974	Pass	1975	Pass	1976	Pass
1977	Pass	1978	Pass	1979	Pass	1980	Pass
1981	Pass	1982	Pass	1983	Pass	1984	Pass
1985	Pass	1986	Pass	1987	Pass	1988	Pass
1989	Pass	1990	Pass	1991	Pass	1992	Pass
1993	Pass	1994	Pass	1995	Pass	1996	Pass
1997	Pass	1998	Pass	1999	Pass	2000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory