

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/012/26	Model No.: KFKHQ-6	Date: 24-01-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 012/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00111 To 120 And 115A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 115A and removed from the Lot/Batch							
111	Pass	112	Pass	113	Pass	114	Pass
115	Pass	116	Pass	117	Pass	118	Pass
119	Pass	120	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory