

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/026/26	Model No.: KFARQ-6-90%	Date: 17-01-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 026/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 02501 To 2600 And 2505A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 2505A and removed from the Lot/Batch							
2501	Pass	2502	Pass	2503	Pass	2504	Pass
2505	Pass	2506	Pass	2507	Pass	2508	Pass
2509	Pass	2510	Pass	2511	Pass	2512	Pass
2513	Pass	2514	Pass	2515	Pass	2516	Pass
2517	Pass	2518	Pass	2519	Pass	2520	Pass
2521	Pass	2522	Pass	2523	Pass	2524	Pass
2525	Pass	2526	Pass	2527	Pass	2528	Pass
2529	Pass	2530	Pass	2531	Pass	2532	Pass
2533	Pass	2534	Pass	2535	Pass	2536	Pass
2537	Pass	2538	Pass	2539	Pass	2540	Pass
2541	Pass	2542	Pass	2543	Pass	2544	Pass
2545	Pass	2546	Pass	2547	Pass	2548	Pass
2549	Pass	2550	Pass	2551	Pass	2552	Pass
2553	Pass	2554	Pass	2555	Pass	2556	Pass
2557	Pass	2558	Pass	2559	Pass	2560	Pass
2561	Pass	2562	Pass	2563	Pass	2564	Pass
2565	Pass	2566	Pass	2567	Pass	2568	Pass
2569	Pass	2570	Pass	2571	Pass	2572	Pass
2573	Pass	2574	Pass	2575	Pass	2576	Pass
2577	Pass	2578	Pass	2579	Pass	2580	Pass
2581	Pass	2582	Pass	2583	Pass	2584	Pass
2585	Pass	2586	Pass	2587	Pass	2588	Pass
2589	Pass	2590	Pass	2591	Pass	2592	Pass
2593	Pass	2594	Pass	2595	Pass	2596	Pass
2597	Pass	2598	Pass	2599	Pass	2600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory