

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/090/26	Model No.: MARQ-6-50%	Date: 01-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 090/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 08901 To 9000 And 8905A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 8905A and removed from the Lot/Batch							
8901	Pass	8902	Pass	8903	Pass	8904	Pass
8905	Pass	8906	Pass	8907	Pass	8908	Pass
8909	Pass	8910	Pass	8911	Pass	8912	Pass
8913	Pass	8914	Pass	8915	Pass	8916	Pass
8917	Pass	8918	Pass	8919	Pass	8920	Pass
8921	Pass	8922	Pass	8923	Pass	8924	Pass
8925	Pass	8926	Pass	8927	Pass	8928	Pass
8929	Pass	8930	Pass	8931	Pass	8932	Pass
8933	Pass	8934	Pass	8935	Pass	8936	Pass
8937	Pass	8938	Pass	8939	Pass	8940	Pass
8941	Pass	8942	Pass	8943	Pass	8944	Pass
8945	Pass	8946	Pass	8947	Pass	8948	Pass
8949	Pass	8950	Pass	8951	Pass	8952	Pass
8953	Pass	8954	Pass	8955	Pass	8956	Pass
8957	Pass	8958	Pass	8959	Pass	8960	Pass
8961	Pass	8962	Pass	8963	Pass	8964	Pass
8965	Pass	8966	Pass	8967	Pass	8968	Pass
8969	Pass	8970	Pass	8971	Pass	8972	Pass
8973	Pass	8974	Pass	8975	Pass	8976	Pass
8977	Pass	8978	Pass	8979	Pass	8980	Pass
8981	Pass	8982	Pass	8983	Pass	8984	Pass
8985	Pass	8986	Pass	8987	Pass	8988	Pass
8989	Pass	8990	Pass	8991	Pass	8992	Pass
8993	Pass	8994	Pass	8995	Pass	8996	Pass
8997	Pass	8998	Pass	8999	Pass	9000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory