

HYDRO PRESSURE TEST

TC No.: HPT/F6/SP/RQ/007/25	Model No.: KFMSRQ-6	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFMSRQ-6-Kanex M Foam SP Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFMSRQ6 007/25	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00061 To 70 And 65A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 65A and removed from the Lot/Batch							
61	Pass	62	Pass	63	Pass	64	Pass
65	Pass	66	Pass	67	Pass	68	Pass
69	Pass	70	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory