

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/088/26	Model No.: MARQ-6-50%	Date: 01-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 088/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 08701 To 8800 And 8705A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 8705A and removed from the Lot/Batch							
8701	Pass	8702	Pass	8703	Pass	8704	Pass
8705	Pass	8706	Pass	8707	Pass	8708	Pass
8709	Pass	8710	Pass	8711	Pass	8712	Pass
8713	Pass	8714	Pass	8715	Pass	8716	Pass
8717	Pass	8718	Pass	8719	Pass	8720	Pass
8721	Pass	8722	Pass	8723	Pass	8724	Pass
8725	Pass	8726	Pass	8727	Pass	8728	Pass
8729	Pass	8730	Pass	8731	Pass	8732	Pass
8733	Pass	8734	Pass	8735	Pass	8736	Pass
8737	Pass	8738	Pass	8739	Pass	8740	Pass
8741	Pass	8742	Pass	8743	Pass	8744	Pass
8745	Pass	8746	Pass	8747	Pass	8748	Pass
8749	Pass	8750	Pass	8751	Pass	8752	Pass
8753	Pass	8754	Pass	8755	Pass	8756	Pass
8757	Pass	8758	Pass	8759	Pass	8760	Pass
8761	Pass	8762	Pass	8763	Pass	8764	Pass
8765	Pass	8766	Pass	8767	Pass	8768	Pass
8769	Pass	8770	Pass	8771	Pass	8772	Pass
8773	Pass	8774	Pass	8775	Pass	8776	Pass
8777	Pass	8778	Pass	8779	Pass	8780	Pass
8781	Pass	8782	Pass	8783	Pass	8784	Pass
8785	Pass	8786	Pass	8787	Pass	8788	Pass
8789	Pass	8790	Pass	8791	Pass	8792	Pass
8793	Pass	8794	Pass	8795	Pass	8796	Pass
8797	Pass	8798	Pass	8799	Pass	8800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory