

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/052/26     | Model No.: MARQ-6-40%                                          | Date: 01-03-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ40%6 052/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 05101 To 5200 And 5105A                                      |                  |
| Month of Manufacturing            | : Mar/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 5105A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 5101                                                         | Pass   | 5102     | Pass   | 5103     | Pass   | 5104     | Pass   |
| 5105                                                         | Pass   | 5106     | Pass   | 5107     | Pass   | 5108     | Pass   |
| 5109                                                         | Pass   | 5110     | Pass   | 5111     | Pass   | 5112     | Pass   |
| 5113                                                         | Pass   | 5114     | Pass   | 5115     | Pass   | 5116     | Pass   |
| 5117                                                         | Pass   | 5118     | Pass   | 5119     | Pass   | 5120     | Pass   |
| 5121                                                         | Pass   | 5122     | Pass   | 5123     | Pass   | 5124     | Pass   |
| 5125                                                         | Pass   | 5126     | Pass   | 5127     | Pass   | 5128     | Pass   |
| 5129                                                         | Pass   | 5130     | Pass   | 5131     | Pass   | 5132     | Pass   |
| 5133                                                         | Pass   | 5134     | Pass   | 5135     | Pass   | 5136     | Pass   |
| 5137                                                         | Pass   | 5138     | Pass   | 5139     | Pass   | 5140     | Pass   |
| 5141                                                         | Pass   | 5142     | Pass   | 5143     | Pass   | 5144     | Pass   |
| 5145                                                         | Pass   | 5146     | Pass   | 5147     | Pass   | 5148     | Pass   |
| 5149                                                         | Pass   | 5150     | Pass   | 5151     | Pass   | 5152     | Pass   |
| 5153                                                         | Pass   | 5154     | Pass   | 5155     | Pass   | 5156     | Pass   |
| 5157                                                         | Pass   | 5158     | Pass   | 5159     | Pass   | 5160     | Pass   |
| 5161                                                         | Pass   | 5162     | Pass   | 5163     | Pass   | 5164     | Pass   |
| 5165                                                         | Pass   | 5166     | Pass   | 5167     | Pass   | 5168     | Pass   |
| 5169                                                         | Pass   | 5170     | Pass   | 5171     | Pass   | 5172     | Pass   |
| 5173                                                         | Pass   | 5174     | Pass   | 5175     | Pass   | 5176     | Pass   |
| 5177                                                         | Pass   | 5178     | Pass   | 5179     | Pass   | 5180     | Pass   |
| 5181                                                         | Pass   | 5182     | Pass   | 5183     | Pass   | 5184     | Pass   |
| 5185                                                         | Pass   | 5186     | Pass   | 5187     | Pass   | 5188     | Pass   |
| 5189                                                         | Pass   | 5190     | Pass   | 5191     | Pass   | 5192     | Pass   |
| 5193                                                         | Pass   | 5194     | Pass   | 5195     | Pass   | 5196     | Pass   |
| 5197                                                         | Pass   | 5198     | Pass   | 5199     | Pass   | 5200     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**


 SIHOR  
 (GUJARAT)

**Authorized Signatory**