

# HYDRO PRESSURE TEST

|                                   |                                                                        |                  |
|-----------------------------------|------------------------------------------------------------------------|------------------|
| TC No.: HPT/F45/RQ/010/26         | Model No.: KFMRQ-45                                                    | Date: 17-02-2026 |
| Type and Capacity of Extinguisher | : KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr. |                  |
| Batch Number                      | : KFMRQ45 010/26                                                       |                  |
| Batch Quantity                    | : 50.00 Nos.                                                           |                  |
| Serial Numbers                    | : 00451 To 500                                                         |                  |
| Month of Manufacturing            | : Feb/26                                                               |                  |

| Sr. Nos.                                                                                   | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on Cylinder Sr.No. 5A and which is removed from the batch (1st batch) |        |          |        |          |        |          |        |
| 451                                                                                        | Pass   | 452      | Pass   | 453      | Pass   | 454      | Pass   |
| 455                                                                                        | Pass   | 456      | Pass   | 457      | Pass   | 458      | Pass   |
| 459                                                                                        | Pass   | 460      | Pass   | 461      | Pass   | 462      | Pass   |
| 463                                                                                        | Pass   | 464      | Pass   | 465      | Pass   | 466      | Pass   |
| 467                                                                                        | Pass   | 468      | Pass   | 469      | Pass   | 470      | Pass   |
| 471                                                                                        | Pass   | 472      | Pass   | 473      | Pass   | 474      | Pass   |
| 475                                                                                        | Pass   | 476      | Pass   | 477      | Pass   | 478      | Pass   |
| 479                                                                                        | Pass   | 480      | Pass   | 481      | Pass   | 482      | Pass   |
| 483                                                                                        | Pass   | 484      | Pass   | 485      | Pass   | 486      | Pass   |
| 487                                                                                        | Pass   | 488      | Pass   | 489      | Pass   | 490      | Pass   |
| 491                                                                                        | Pass   | 492      | Pass   | 493      | Pass   | 494      | Pass   |
| 495                                                                                        | Pass   | 496      | Pass   | 497      | Pass   | 498      | Pass   |
| 499                                                                                        | Pass   | 500      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



**Authorized Signatory**