

HELIUM LEAK DETECTION TEST

TC No.: HLD/MOD5/CA/HQ/009/25	Model No.: KMCHQ-5-FE36	Date: 05-07-2025
Type and Capacity of Extinguisher	: KMCHQ-5-FE36-Kanex Modular Clean Agent Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCHQ5 009/25	
Batch Quantity	: 50 Nos.	
Serial Numbers	: 00401 To 450	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
401	Pass	402	Pass	403	Pass	404	Pass
405	Pass	406	Pass	407	Pass	408	Pass
409	Pass	410	Pass	411	Pass	412	Pass
413	Pass	414	Pass	415	Pass	416	Pass
417	Pass	418	Pass	419	Pass	420	Pass
421	Pass	422	Pass	423	Pass	424	Pass
425	Pass	426	Pass	427	Pass	428	Pass
429	Pass	430	Pass	431	Pass	432	Pass
433	Pass	434	Pass	435	Pass	436	Pass
437	Pass	438	Pass	439	Pass	440	Pass
441	Pass	442	Pass	443	Pass	444	Pass
445	Pass	446	Pass	447	Pass	448	Pass
449	Pass	450	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory