

# HYDRO PRESSURE TEST

|                                   |                                                                         |                  |
|-----------------------------------|-------------------------------------------------------------------------|------------------|
| TC No.: HPT/MOD5/A50/RQ/013/26    | Model No.: KMPRQ-5-50%                                                  | Date: 24-02-2026 |
| Type and Capacity of Extinguisher | : KMPRQ-5-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg. |                  |
| Batch Number                      | : KMPRQ50%5 013/26                                                      |                  |
| Batch Quantity                    | : 100.00 Nos.                                                           |                  |
| Serial Numbers                    | : 01201 To 1300                                                         |                  |
| Month of Manufacturing            | : Feb/26                                                                |                  |

| Sr. Nos.                                                             | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|----------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 01201 To 1300 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1201                                                                 | Pass   | 1202     | Pass   | 1203     | Pass   | 1204     | Pass   |
| 1205                                                                 | Pass   | 1206     | Pass   | 1207     | Pass   | 1208     | Pass   |
| 1209                                                                 | Pass   | 1210     | Pass   | 1211     | Pass   | 1212     | Pass   |
| 1213                                                                 | Pass   | 1214     | Pass   | 1215     | Pass   | 1216     | Pass   |
| 1217                                                                 | Pass   | 1218     | Pass   | 1219     | Pass   | 1220     | Pass   |
| 1221                                                                 | Pass   | 1222     | Pass   | 1223     | Pass   | 1224     | Pass   |
| 1225                                                                 | Pass   | 1226     | Pass   | 1227     | Pass   | 1228     | Pass   |
| 1229                                                                 | Pass   | 1230     | Pass   | 1231     | Pass   | 1232     | Pass   |
| 1233                                                                 | Pass   | 1234     | Pass   | 1235     | Pass   | 1236     | Pass   |
| 1237                                                                 | Pass   | 1238     | Pass   | 1239     | Pass   | 1240     | Pass   |
| 1241                                                                 | Pass   | 1242     | Pass   | 1243     | Pass   | 1244     | Pass   |
| 1245                                                                 | Pass   | 1246     | Pass   | 1247     | Pass   | 1248     | Pass   |
| 1249                                                                 | Pass   | 1250     | Pass   | 1251     | Pass   | 1252     | Pass   |
| 1253                                                                 | Pass   | 1254     | Pass   | 1255     | Pass   | 1256     | Pass   |
| 1257                                                                 | Pass   | 1258     | Pass   | 1259     | Pass   | 1260     | Pass   |
| 1261                                                                 | Pass   | 1262     | Pass   | 1263     | Pass   | 1264     | Pass   |
| 1265                                                                 | Pass   | 1266     | Pass   | 1267     | Pass   | 1268     | Pass   |
| 1269                                                                 | Pass   | 1270     | Pass   | 1271     | Pass   | 1272     | Pass   |
| 1273                                                                 | Pass   | 1274     | Pass   | 1275     | Pass   | 1276     | Pass   |
| 1277                                                                 | Pass   | 1278     | Pass   | 1279     | Pass   | 1280     | Pass   |
| 1281                                                                 | Pass   | 1282     | Pass   | 1283     | Pass   | 1284     | Pass   |
| 1285                                                                 | Pass   | 1286     | Pass   | 1287     | Pass   | 1288     | Pass   |
| 1289                                                                 | Pass   | 1290     | Pass   | 1291     | Pass   | 1292     | Pass   |
| 1293                                                                 | Pass   | 1294     | Pass   | 1295     | Pass   | 1296     | Pass   |
| 1297                                                                 | Pass   | 1298     | Pass   | 1299     | Pass   | 1300     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**


 SIHOR  
 (GUJARAT)

**Authorized Signatory**