

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/050/26	Model No.: MARQ-6-40%	Date: 24-02-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 050/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 04901 To 5000 And 4905A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 4905A and removed from the Lot/Batch							
4901	Pass	4902	Pass	4903	Pass	4904	Pass
4905	Pass	4906	Pass	4907	Pass	4908	Pass
4909	Pass	4910	Pass	4911	Pass	4912	Pass
4913	Pass	4914	Pass	4915	Pass	4916	Pass
4917	Pass	4918	Pass	4919	Pass	4920	Pass
4921	Pass	4922	Pass	4923	Pass	4924	Pass
4925	Pass	4926	Pass	4927	Pass	4928	Pass
4929	Pass	4930	Pass	4931	Pass	4932	Pass
4933	Pass	4934	Pass	4935	Pass	4936	Pass
4937	Pass	4938	Pass	4939	Pass	4940	Pass
4941	Pass	4942	Pass	4943	Pass	4944	Pass
4945	Pass	4946	Pass	4947	Pass	4948	Pass
4949	Pass	4950	Pass	4951	Pass	4952	Pass
4953	Pass	4954	Pass	4955	Pass	4956	Pass
4957	Pass	4958	Pass	4959	Pass	4960	Pass
4961	Pass	4962	Pass	4963	Pass	4964	Pass
4965	Pass	4966	Pass	4967	Pass	4968	Pass
4969	Pass	4970	Pass	4971	Pass	4972	Pass
4973	Pass	4974	Pass	4975	Pass	4976	Pass
4977	Pass	4978	Pass	4979	Pass	4980	Pass
4981	Pass	4982	Pass	4983	Pass	4984	Pass
4985	Pass	4986	Pass	4987	Pass	4988	Pass
4989	Pass	4990	Pass	4991	Pass	4992	Pass
4993	Pass	4994	Pass	4995	Pass	4996	Pass
4997	Pass	4998	Pass	4999	Pass	5000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory