

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/091/26	Model No.: MARQ-6-50%	Date: 01-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 091/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 09001 To 9100 And 9005A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 9005A and removed from the Lot/Batch							
9001	Pass	9002	Pass	9003	Pass	9004	Pass
9005	Pass	9006	Pass	9007	Pass	9008	Pass
9009	Pass	9010	Pass	9011	Pass	9012	Pass
9013	Pass	9014	Pass	9015	Pass	9016	Pass
9017	Pass	9018	Pass	9019	Pass	9020	Pass
9021	Pass	9022	Pass	9023	Pass	9024	Pass
9025	Pass	9026	Pass	9027	Pass	9028	Pass
9029	Pass	9030	Pass	9031	Pass	9032	Pass
9033	Pass	9034	Pass	9035	Pass	9036	Pass
9037	Pass	9038	Pass	9039	Pass	9040	Pass
9041	Pass	9042	Pass	9043	Pass	9044	Pass
9045	Pass	9046	Pass	9047	Pass	9048	Pass
9049	Pass	9050	Pass	9051	Pass	9052	Pass
9053	Pass	9054	Pass	9055	Pass	9056	Pass
9057	Pass	9058	Pass	9059	Pass	9060	Pass
9061	Pass	9062	Pass	9063	Pass	9064	Pass
9065	Pass	9066	Pass	9067	Pass	9068	Pass
9069	Pass	9070	Pass	9071	Pass	9072	Pass
9073	Pass	9074	Pass	9075	Pass	9076	Pass
9077	Pass	9078	Pass	9079	Pass	9080	Pass
9081	Pass	9082	Pass	9083	Pass	9084	Pass
9085	Pass	9086	Pass	9087	Pass	9088	Pass
9089	Pass	9090	Pass	9091	Pass	9092	Pass
9093	Pass	9094	Pass	9095	Pass	9096	Pass
9097	Pass	9098	Pass	9099	Pass	9100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory