

HYDRO PRESSURE TEST

TC No.: HPT/WM9/HQ/015/26	Model No.: KFWMSHQ-9	Date: 17-02-2026
Type and Capacity of Extinguisher	: KFWMSHQ-9-Water Mist Type Portable Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFWMSHQ9 015/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00141 To 150 And 145A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 145A and removed from the Lot/Batch							
141	Pass	142	Pass	143	Pass	144	Pass
145	Pass	146	Pass	147	Pass	148	Pass
149	Pass	150	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory