

HYDRO PRESSURE TEST

TC No.: HPT/MOD2/A90/RQ/002/25	Model No.: KMPRQ-2-90%	Date: 10-05-2025
Type and Capacity of Extinguisher	: KMPRQ-2-90%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KMPRQ90%2 002/25	
Batch Quantity	: 20.00 Nos.	
Serial Numbers	: 00021 To 40	
Month of Manufacturing	: May/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00021 To 40 and removed from the Lot/Batch							
21	Pass	22	Pass	23	Pass	24	Pass
25	Pass	26	Pass	27	Pass	28	Pass
29	Pass	30	Pass	31	Pass	32	Pass
33	Pass	34	Pass	35	Pass	36	Pass
37	Pass	38	Pass	39	Pass	40	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory