

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/077/26	Model No.: KFARQ-6-50%	Date: 17-02-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 077/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 07601 To 7700 And 7605A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 7605A and removed from the Lot/Batch							
7601	Pass	7602	Pass	7603	Pass	7604	Pass
7605	Pass	7606	Pass	7607	Pass	7608	Pass
7609	Pass	7610	Pass	7611	Pass	7612	Pass
7613	Pass	7614	Pass	7615	Pass	7616	Pass
7617	Pass	7618	Pass	7619	Pass	7620	Pass
7621	Pass	7622	Pass	7623	Pass	7624	Pass
7625	Pass	7626	Pass	7627	Pass	7628	Pass
7629	Pass	7630	Pass	7631	Pass	7632	Pass
7633	Pass	7634	Pass	7635	Pass	7636	Pass
7637	Pass	7638	Pass	7639	Pass	7640	Pass
7641	Pass	7642	Pass	7643	Pass	7644	Pass
7645	Pass	7646	Pass	7647	Pass	7648	Pass
7649	Pass	7650	Pass	7651	Pass	7652	Pass
7653	Pass	7654	Pass	7655	Pass	7656	Pass
7657	Pass	7658	Pass	7659	Pass	7660	Pass
7661	Pass	7662	Pass	7663	Pass	7664	Pass
7665	Pass	7666	Pass	7667	Pass	7668	Pass
7669	Pass	7670	Pass	7671	Pass	7672	Pass
7673	Pass	7674	Pass	7675	Pass	7676	Pass
7677	Pass	7678	Pass	7679	Pass	7680	Pass
7681	Pass	7682	Pass	7683	Pass	7684	Pass
7685	Pass	7686	Pass	7687	Pass	7688	Pass
7689	Pass	7690	Pass	7691	Pass	7692	Pass
7693	Pass	7694	Pass	7695	Pass	7696	Pass
7697	Pass	7698	Pass	7699	Pass	7700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory