

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/056/26	Model No.: MARQ-6-40%	Date: 09-03-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 056/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 05501 To 5600 And 5505A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5505A and removed from the Lot/Batch							
5501	Pass	5502	Pass	5503	Pass	5504	Pass
5505	Pass	5506	Pass	5507	Pass	5508	Pass
5509	Pass	5510	Pass	5511	Pass	5512	Pass
5513	Pass	5514	Pass	5515	Pass	5516	Pass
5517	Pass	5518	Pass	5519	Pass	5520	Pass
5521	Pass	5522	Pass	5523	Pass	5524	Pass
5525	Pass	5526	Pass	5527	Pass	5528	Pass
5529	Pass	5530	Pass	5531	Pass	5532	Pass
5533	Pass	5534	Pass	5535	Pass	5536	Pass
5537	Pass	5538	Pass	5539	Pass	5540	Pass
5541	Pass	5542	Pass	5543	Pass	5544	Pass
5545	Pass	5546	Pass	5547	Pass	5548	Pass
5549	Pass	5550	Pass	5551	Pass	5552	Pass
5553	Pass	5554	Pass	5555	Pass	5556	Pass
5557	Pass	5558	Pass	5559	Pass	5560	Pass
5561	Pass	5562	Pass	5563	Pass	5564	Pass
5565	Pass	5566	Pass	5567	Pass	5568	Pass
5569	Pass	5570	Pass	5571	Pass	5572	Pass
5573	Pass	5574	Pass	5575	Pass	5576	Pass
5577	Pass	5578	Pass	5579	Pass	5580	Pass
5581	Pass	5582	Pass	5583	Pass	5584	Pass
5585	Pass	5586	Pass	5587	Pass	5588	Pass
5589	Pass	5590	Pass	5591	Pass	5592	Pass
5593	Pass	5594	Pass	5595	Pass	5596	Pass
5597	Pass	5598	Pass	5599	Pass	5600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory