

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/009/26	Model No.: MARQ-9-50%	Date: 12-03-2026
Type and Capacity of Extinguisher	: MARQ-9-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	
Batch Number	: MARQ50%9 009/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 00801 To 900 And 805A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 805A and removed from the Lot/Batch							
801	Pass	802	Pass	803	Pass	804	Pass
805	Pass	806	Pass	807	Pass	808	Pass
809	Pass	810	Pass	811	Pass	812	Pass
813	Pass	814	Pass	815	Pass	816	Pass
817	Pass	818	Pass	819	Pass	820	Pass
821	Pass	822	Pass	823	Pass	824	Pass
825	Pass	826	Pass	827	Pass	828	Pass
829	Pass	830	Pass	831	Pass	832	Pass
833	Pass	834	Pass	835	Pass	836	Pass
837	Pass	838	Pass	839	Pass	840	Pass
841	Pass	842	Pass	843	Pass	844	Pass
845	Pass	846	Pass	847	Pass	848	Pass
849	Pass	850	Pass	851	Pass	852	Pass
853	Pass	854	Pass	855	Pass	856	Pass
857	Pass	858	Pass	859	Pass	860	Pass
861	Pass	862	Pass	863	Pass	864	Pass
865	Pass	866	Pass	867	Pass	868	Pass
869	Pass	870	Pass	871	Pass	872	Pass
873	Pass	874	Pass	875	Pass	876	Pass
877	Pass	878	Pass	879	Pass	880	Pass
881	Pass	882	Pass	883	Pass	884	Pass
885	Pass	886	Pass	887	Pass	888	Pass
889	Pass	890	Pass	891	Pass	892	Pass
893	Pass	894	Pass	895	Pass	896	Pass
897	Pass	898	Pass	899	Pass	900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory