

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/076/26	Model No.: KFARQ-6-50%	Date: 17-02-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 076/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 07501 To 7600 And 7505A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 7505A and removed from the Lot/Batch							
7501	Pass	7502	Pass	7503	Pass	7504	Pass
7505	Pass	7506	Pass	7507	Pass	7508	Pass
7509	Pass	7510	Pass	7511	Pass	7512	Pass
7513	Pass	7514	Pass	7515	Pass	7516	Pass
7517	Pass	7518	Pass	7519	Pass	7520	Pass
7521	Pass	7522	Pass	7523	Pass	7524	Pass
7525	Pass	7526	Pass	7527	Pass	7528	Pass
7529	Pass	7530	Pass	7531	Pass	7532	Pass
7533	Pass	7534	Pass	7535	Pass	7536	Pass
7537	Pass	7538	Pass	7539	Pass	7540	Pass
7541	Pass	7542	Pass	7543	Pass	7544	Pass
7545	Pass	7546	Pass	7547	Pass	7548	Pass
7549	Pass	7550	Pass	7551	Pass	7552	Pass
7553	Pass	7554	Pass	7555	Pass	7556	Pass
7557	Pass	7558	Pass	7559	Pass	7560	Pass
7561	Pass	7562	Pass	7563	Pass	7564	Pass
7565	Pass	7566	Pass	7567	Pass	7568	Pass
7569	Pass	7570	Pass	7571	Pass	7572	Pass
7573	Pass	7574	Pass	7575	Pass	7576	Pass
7577	Pass	7578	Pass	7579	Pass	7580	Pass
7581	Pass	7582	Pass	7583	Pass	7584	Pass
7585	Pass	7586	Pass	7587	Pass	7588	Pass
7589	Pass	7590	Pass	7591	Pass	7592	Pass
7593	Pass	7594	Pass	7595	Pass	7596	Pass
7597	Pass	7598	Pass	7599	Pass	7600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory