

HYDRO PRESSURE TEST

TC No.: HPT/MOD2/CA/RQ/001/26	Model No.: KMCRQ-2	Date: 17-02-2026
Type and Capacity of Extinguisher	: KMCRQ-2-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KMCRQ2 001/26	
Batch Quantity	: 20.00 Nos.	
Serial Numbers	: 00001 To 20	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00001 To 20 and removed from the Lot/Batch							
1	Pass	2	Pass	3	Pass	4	Pass
5	Pass	6	Pass	7	Pass	8	Pass
9	Pass	10	Pass	11	Pass	12	Pass
13	Pass	14	Pass	15	Pass	16	Pass
17	Pass	18	Pass	19	Pass	20	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory