



# Warranty Certificate

Date: 20-03-2026**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Wow Momo Foods Pvt. Ltd.**Warranty Start Date:** 20-03-2026**Warranty End Date:** 19-03-2029.

This is to certify that the below extinguishers are warranted for a period of **3** year from the date of supply against any of Manufacturing/Quality defects.

**NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.**

| Sr.No. | Type & Capacity of Extinguishers                                 | Quantity | Sr. Nos.            |
|--------|------------------------------------------------------------------|----------|---------------------|
| 1      | KFARQ-2-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.    | 1        | As Per Annexure – I |
| 2      | KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.    | 1        | As Per Annexure – I |
| 3      | KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg. | 2        | As Per Annexure – I |
| 4      | KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.      | 4        | As Per Annexure – I |

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/K/009346 Dated: 20-03-2026 P.O.No. PO-WM-000117975** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**