

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/028/26	Model No.: KFKHQ-6	Date: 01-03-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 028/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00271 To 280 And 275A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 275A and removed from the Lot/Batch							
271	Pass	272	Pass	273	Pass	274	Pass
275	Pass	276	Pass	277	Pass	278	Pass
279	Pass	280	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory