

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/058/26     | Model No.: MARQ-6-40%                                          | Date: 09-03-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ40%6 058/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 05701 To 5800 And 5705A                                      |                  |
| Month of Manufacturing            | : Mar/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 5705A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 5701                                                         | Pass   | 5702     | Pass   | 5703     | Pass   | 5704     | Pass   |
| 5705                                                         | Pass   | 5706     | Pass   | 5707     | Pass   | 5708     | Pass   |
| 5709                                                         | Pass   | 5710     | Pass   | 5711     | Pass   | 5712     | Pass   |
| 5713                                                         | Pass   | 5714     | Pass   | 5715     | Pass   | 5716     | Pass   |
| 5717                                                         | Pass   | 5718     | Pass   | 5719     | Pass   | 5720     | Pass   |
| 5721                                                         | Pass   | 5722     | Pass   | 5723     | Pass   | 5724     | Pass   |
| 5725                                                         | Pass   | 5726     | Pass   | 5727     | Pass   | 5728     | Pass   |
| 5729                                                         | Pass   | 5730     | Pass   | 5731     | Pass   | 5732     | Pass   |
| 5733                                                         | Pass   | 5734     | Pass   | 5735     | Pass   | 5736     | Pass   |
| 5737                                                         | Pass   | 5738     | Pass   | 5739     | Pass   | 5740     | Pass   |
| 5741                                                         | Pass   | 5742     | Pass   | 5743     | Pass   | 5744     | Pass   |
| 5745                                                         | Pass   | 5746     | Pass   | 5747     | Pass   | 5748     | Pass   |
| 5749                                                         | Pass   | 5750     | Pass   | 5751     | Pass   | 5752     | Pass   |
| 5753                                                         | Pass   | 5754     | Pass   | 5755     | Pass   | 5756     | Pass   |
| 5757                                                         | Pass   | 5758     | Pass   | 5759     | Pass   | 5760     | Pass   |
| 5761                                                         | Pass   | 5762     | Pass   | 5763     | Pass   | 5764     | Pass   |
| 5765                                                         | Pass   | 5766     | Pass   | 5767     | Pass   | 5768     | Pass   |
| 5769                                                         | Pass   | 5770     | Pass   | 5771     | Pass   | 5772     | Pass   |
| 5773                                                         | Pass   | 5774     | Pass   | 5775     | Pass   | 5776     | Pass   |
| 5777                                                         | Pass   | 5778     | Pass   | 5779     | Pass   | 5780     | Pass   |
| 5781                                                         | Pass   | 5782     | Pass   | 5783     | Pass   | 5784     | Pass   |
| 5785                                                         | Pass   | 5786     | Pass   | 5787     | Pass   | 5788     | Pass   |
| 5789                                                         | Pass   | 5790     | Pass   | 5791     | Pass   | 5792     | Pass   |
| 5793                                                         | Pass   | 5794     | Pass   | 5795     | Pass   | 5796     | Pass   |
| 5797                                                         | Pass   | 5798     | Pass   | 5799     | Pass   | 5800     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**