

HELIUM LEAK DETECTION TEST

TC No.: HLD/A9/K/HQ/010/26	Model No.: KFKHQ-9	Date: 03-03-2026
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 010/26	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00091 To 100	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
91	Pass	92	Pass	93	Pass	94	Pass
95	Pass	96	Pass	97	Pass	98	Pass
99	Pass	100	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory