

HYDRO PRESSURE TEST

TC No.: HPT/A9/K/HQ/009/26	Model No.: KFKHQ-9	Date: 01-03-2026
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 009/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00081 To 90	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00081 To 90 and removed from the Lot/Batch							
81	Pass	82	Pass	83	Pass	84	Pass
85	Pass	86	Pass	87	Pass	88	Pass
89	Pass	90	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory