

# HYDRO PRESSURE TEST

|                                   |                                                                       |                  |
|-----------------------------------|-----------------------------------------------------------------------|------------------|
| TC No.: HPT/A6/S/RQ/026/25        | Model No.: KFSRQ-6-S                                                  | Date: 20-09-2025 |
| Type and Capacity of Extinguisher | : KFSRQ-6-S-Kanex BC Dry Powder (SBC) SP Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFSRQ6S 026/25                                                      |                  |
| Batch Quantity                    | : 51.00 Nos.                                                          |                  |
| Serial Numbers                    | : 01251 To 1300 And 1255A                                             |                  |
| Month of Manufacturing            | : Sep/25                                                              |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 1255A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1251                                                         | Pass   | 1252     | Pass   | 1253     | Pass   | 1254     | Pass   |
| 1255                                                         | Pass   | 1256     | Pass   | 1257     | Pass   | 1258     | Pass   |
| 1259                                                         | Pass   | 1260     | Pass   | 1261     | Pass   | 1262     | Pass   |
| 1263                                                         | Pass   | 1264     | Pass   | 1265     | Pass   | 1266     | Pass   |
| 1267                                                         | Pass   | 1268     | Pass   | 1269     | Pass   | 1270     | Pass   |
| 1271                                                         | Pass   | 1272     | Pass   | 1273     | Pass   | 1274     | Pass   |
| 1275                                                         | Pass   | 1276     | Pass   | 1277     | Pass   | 1278     | Pass   |
| 1279                                                         | Pass   | 1280     | Pass   | 1281     | Pass   | 1282     | Pass   |
| 1283                                                         | Pass   | 1284     | Pass   | 1285     | Pass   | 1286     | Pass   |
| 1287                                                         | Pass   | 1288     | Pass   | 1289     | Pass   | 1290     | Pass   |
| 1291                                                         | Pass   | 1292     | Pass   | 1293     | Pass   | 1294     | Pass   |
| 1295                                                         | Pass   | 1296     | Pass   | 1297     | Pass   | 1298     | Pass   |
| 1299                                                         | Pass   | 1300     | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**