

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/112/26	Model No.: MARQ-6-50%	Date: 09-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 112/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 11101 To 11200 And 11105A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 11105A and removed from the Lot/Batch							
11101	Pass	11102	Pass	11103	Pass	11104	Pass
11105	Pass	11106	Pass	11107	Pass	11108	Pass
11109	Pass	11110	Pass	11111	Pass	11112	Pass
11113	Pass	11114	Pass	11115	Pass	11116	Pass
11117	Pass	11118	Pass	11119	Pass	11120	Pass
11121	Pass	11122	Pass	11123	Pass	11124	Pass
11125	Pass	11126	Pass	11127	Pass	11128	Pass
11129	Pass	11130	Pass	11131	Pass	11132	Pass
11133	Pass	11134	Pass	11135	Pass	11136	Pass
11137	Pass	11138	Pass	11139	Pass	11140	Pass
11141	Pass	11142	Pass	11143	Pass	11144	Pass
11145	Pass	11146	Pass	11147	Pass	11148	Pass
11149	Pass	11150	Pass	11151	Pass	11152	Pass
11153	Pass	11154	Pass	11155	Pass	11156	Pass
11157	Pass	11158	Pass	11159	Pass	11160	Pass
11161	Pass	11162	Pass	11163	Pass	11164	Pass
11165	Pass	11166	Pass	11167	Pass	11168	Pass
11169	Pass	11170	Pass	11171	Pass	11172	Pass
11173	Pass	11174	Pass	11175	Pass	11176	Pass
11177	Pass	11178	Pass	11179	Pass	11180	Pass
11181	Pass	11182	Pass	11183	Pass	11184	Pass
11185	Pass	11186	Pass	11187	Pass	11188	Pass
11189	Pass	11190	Pass	11191	Pass	11192	Pass
11193	Pass	11194	Pass	11195	Pass	11196	Pass
11197	Pass	11198	Pass	11199	Pass	11200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory