

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/088/26     | Model No.: MARQ-6-40%                                          | Date: 27-03-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ40%6 088/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 08701 To 8800 And 8705A                                      |                  |
| Month of Manufacturing            | : Mar/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 8705A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 8701                                                         | Pass   | 8702     | Pass   | 8703     | Pass   | 8704     | Pass   |
| 8705                                                         | Pass   | 8706     | Pass   | 8707     | Pass   | 8708     | Pass   |
| 8709                                                         | Pass   | 8710     | Pass   | 8711     | Pass   | 8712     | Pass   |
| 8713                                                         | Pass   | 8714     | Pass   | 8715     | Pass   | 8716     | Pass   |
| 8717                                                         | Pass   | 8718     | Pass   | 8719     | Pass   | 8720     | Pass   |
| 8721                                                         | Pass   | 8722     | Pass   | 8723     | Pass   | 8724     | Pass   |
| 8725                                                         | Pass   | 8726     | Pass   | 8727     | Pass   | 8728     | Pass   |
| 8729                                                         | Pass   | 8730     | Pass   | 8731     | Pass   | 8732     | Pass   |
| 8733                                                         | Pass   | 8734     | Pass   | 8735     | Pass   | 8736     | Pass   |
| 8737                                                         | Pass   | 8738     | Pass   | 8739     | Pass   | 8740     | Pass   |
| 8741                                                         | Pass   | 8742     | Pass   | 8743     | Pass   | 8744     | Pass   |
| 8745                                                         | Pass   | 8746     | Pass   | 8747     | Pass   | 8748     | Pass   |
| 8749                                                         | Pass   | 8750     | Pass   | 8751     | Pass   | 8752     | Pass   |
| 8753                                                         | Pass   | 8754     | Pass   | 8755     | Pass   | 8756     | Pass   |
| 8757                                                         | Pass   | 8758     | Pass   | 8759     | Pass   | 8760     | Pass   |
| 8761                                                         | Pass   | 8762     | Pass   | 8763     | Pass   | 8764     | Pass   |
| 8765                                                         | Pass   | 8766     | Pass   | 8767     | Pass   | 8768     | Pass   |
| 8769                                                         | Pass   | 8770     | Pass   | 8771     | Pass   | 8772     | Pass   |
| 8773                                                         | Pass   | 8774     | Pass   | 8775     | Pass   | 8776     | Pass   |
| 8777                                                         | Pass   | 8778     | Pass   | 8779     | Pass   | 8780     | Pass   |
| 8781                                                         | Pass   | 8782     | Pass   | 8783     | Pass   | 8784     | Pass   |
| 8785                                                         | Pass   | 8786     | Pass   | 8787     | Pass   | 8788     | Pass   |
| 8789                                                         | Pass   | 8790     | Pass   | 8791     | Pass   | 8792     | Pass   |
| 8793                                                         | Pass   | 8794     | Pass   | 8795     | Pass   | 8796     | Pass   |
| 8797                                                         | Pass   | 8798     | Pass   | 8799     | Pass   | 8800     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**