

HYDRO PRESSURE TEST

TC No.: HPT/A4/K/HQ/002/26	Model No.: KFKHQ-4	Date: 01-02-2026
Type and Capacity of Extinguisher	: KFKHQ-4-Kanex F Class Kitchen Fire Extinguisher Cap. 4 Ltr.	
Batch Number	: KFKHQ4 002/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00011 To 20	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00011 To 20 and removed from the Lot/Batch							
11	Pass	12	Pass	13	Pass	14	Pass
15	Pass	16	Pass	17	Pass	18	Pass
19	Pass	20	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory