

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/060/26	Model No.: KFARQ-6-90%	Date: 01-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 060/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 05901 To 6000 And 5905A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5905A and removed from the Lot/Batch							
5901	Pass	5902	Pass	5903	Pass	5904	Pass
5905	Pass	5906	Pass	5907	Pass	5908	Pass
5909	Pass	5910	Pass	5911	Pass	5912	Pass
5913	Pass	5914	Pass	5915	Pass	5916	Pass
5917	Pass	5918	Pass	5919	Pass	5920	Pass
5921	Pass	5922	Pass	5923	Pass	5924	Pass
5925	Pass	5926	Pass	5927	Pass	5928	Pass
5929	Pass	5930	Pass	5931	Pass	5932	Pass
5933	Pass	5934	Pass	5935	Pass	5936	Pass
5937	Pass	5938	Pass	5939	Pass	5940	Pass
5941	Pass	5942	Pass	5943	Pass	5944	Pass
5945	Pass	5946	Pass	5947	Pass	5948	Pass
5949	Pass	5950	Pass	5951	Pass	5952	Pass
5953	Pass	5954	Pass	5955	Pass	5956	Pass
5957	Pass	5958	Pass	5959	Pass	5960	Pass
5961	Pass	5962	Pass	5963	Pass	5964	Pass
5965	Pass	5966	Pass	5967	Pass	5968	Pass
5969	Pass	5970	Pass	5971	Pass	5972	Pass
5973	Pass	5974	Pass	5975	Pass	5976	Pass
5977	Pass	5978	Pass	5979	Pass	5980	Pass
5981	Pass	5982	Pass	5983	Pass	5984	Pass
5985	Pass	5986	Pass	5987	Pass	5988	Pass
5989	Pass	5990	Pass	5991	Pass	5992	Pass
5993	Pass	5994	Pass	5995	Pass	5996	Pass
5997	Pass	5998	Pass	5999	Pass	6000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory