

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/110/26	Model No.: MARQ-6-50%	Date: 09-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 110/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 10901 To 11000 And 10905A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 10905A and removed from the Lot/Batch							
10901	Pass	10902	Pass	10903	Pass	10904	Pass
10905	Pass	10906	Pass	10907	Pass	10908	Pass
10909	Pass	10910	Pass	10911	Pass	10912	Pass
10913	Pass	10914	Pass	10915	Pass	10916	Pass
10917	Pass	10918	Pass	10919	Pass	10920	Pass
10921	Pass	10922	Pass	10923	Pass	10924	Pass
10925	Pass	10926	Pass	10927	Pass	10928	Pass
10929	Pass	10930	Pass	10931	Pass	10932	Pass
10933	Pass	10934	Pass	10935	Pass	10936	Pass
10937	Pass	10938	Pass	10939	Pass	10940	Pass
10941	Pass	10942	Pass	10943	Pass	10944	Pass
10945	Pass	10946	Pass	10947	Pass	10948	Pass
10949	Pass	10950	Pass	10951	Pass	10952	Pass
10953	Pass	10954	Pass	10955	Pass	10956	Pass
10957	Pass	10958	Pass	10959	Pass	10960	Pass
10961	Pass	10962	Pass	10963	Pass	10964	Pass
10965	Pass	10966	Pass	10967	Pass	10968	Pass
10969	Pass	10970	Pass	10971	Pass	10972	Pass
10973	Pass	10974	Pass	10975	Pass	10976	Pass
10977	Pass	10978	Pass	10979	Pass	10980	Pass
10981	Pass	10982	Pass	10983	Pass	10984	Pass
10985	Pass	10986	Pass	10987	Pass	10988	Pass
10989	Pass	10990	Pass	10991	Pass	10992	Pass
10993	Pass	10994	Pass	10995	Pass	10996	Pass
10997	Pass	10998	Pass	10999	Pass	11000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory