

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/020/26	Model No.: KMCRQ-5	Date: 17-02-2026
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 020/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 00951 To 1000	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00951 To 1000 and removed from the Lot/Batch							
951	Pass	952	Pass	953	Pass	954	Pass
955	Pass	956	Pass	957	Pass	958	Pass
959	Pass	960	Pass	961	Pass	962	Pass
963	Pass	964	Pass	965	Pass	966	Pass
967	Pass	968	Pass	969	Pass	970	Pass
971	Pass	972	Pass	973	Pass	974	Pass
975	Pass	976	Pass	977	Pass	978	Pass
979	Pass	980	Pass	981	Pass	982	Pass
983	Pass	984	Pass	985	Pass	986	Pass
987	Pass	988	Pass	989	Pass	990	Pass
991	Pass	992	Pass	993	Pass	994	Pass
995	Pass	996	Pass	997	Pass	998	Pass
999	Pass	1000	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory