

# Manufacturer Test Certificate

Doc No: FM-QAC-061

Rev No: 01

Date: 01.06.2023

|                                   |                                                                              |                  |
|-----------------------------------|------------------------------------------------------------------------------|------------------|
| TC No.: MOD10/CA/RQ/028/26        | Model No.: KMCRQ-10                                                          | Date: 20-02-2026 |
| Type and Capacity of Extinguisher | : KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg. |                  |
| Batch Number                      | : KMCRQ10 028/26                                                             |                  |
| Batch Quantity                    | : 10.00 Nos.                                                                 |                  |
| Serial Numbers                    | : 00271 To 280                                                               |                  |
| Month of Manufacturing            | : Feb/26                                                                     |                  |
| Date of Inspection                | : 20-02-2026                                                                 |                  |

| Sr. Nos. | Cl. No. | Tests and Inspection       | Requirements                                                                   | Sampling | Observation  |
|----------|---------|----------------------------|--------------------------------------------------------------------------------|----------|--------------|
| 1        | --      | Extinguishing medium       | HFC 236fa Clean Agent Gas                                                      | One      | Pass         |
| 2        | --      | Design & Construction      | Deep Drawn bodies and MIG welding                                              | One      | Pass         |
| 3        | --      | Applicable Classes of Fire | Suitable for ABC type fires                                                    | All      | Pass         |
| 4        | --      | Propelling Agent           | Nitrogen Gas                                                                   | All      | Pass         |
| 5        | --      | Sensing Element            | Glass Bulb (68 °C)                                                             | One      | Pass         |
| 6        | --      | Working Pressure           | 10 bar                                                                         | All      | Pass         |
| 7        | --      | Hydrostatic Pressure Test  | Test Pressure 35 bar for 2.5 min                                               | All      | Pass         |
| 8        | --      | Burst Pressure Test        | Test Pressure 55 bar for 2 min                                                 | One      | Pass         |
| 9        | --      | Anti Corrosive Treatment   | Phosphating treatment followed by Pure Polyester Powder Coating of 60-80 μ DFT | All      | (80-90μ) DFT |
| 10       | --      | Painting                   | P. O. Red shade as per IS-5                                                    | All      | Pass         |
| 11       | --      | Leakage Test               | All extinguishers passed in the leakage test                                   | All      | Pass         |
| 12       | --      | Performance Test           | Modular should opeprate at desired temprature                                  | One      | Pass         |

**Remarks:** This is to certify that the above mentioned “KANEX” Brand Clean Agent Modulares are gone through the following tests and found satisfactory during the tests.



**Authorized Signatory**