

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/028/26	Model No.: KMCRQ-10	Date: 17-02-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 028/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00271 To 280	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00271 To 280 and removed from the Lot/Batch							
271	Pass	272	Pass	273	Pass	274	Pass
275	Pass	276	Pass	277	Pass	278	Pass
279	Pass	280	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory