

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/014/26	Model No.: KFMRQ-45	Date: 07-03-2026
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 014/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 00651 To 700	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.505A and which is removed from the batch (11th batch)							
651	Pass	652	Pass	653	Pass	654	Pass
655	Pass	656	Pass	657	Pass	658	Pass
659	Pass	660	Pass	661	Pass	662	Pass
663	Pass	664	Pass	665	Pass	666	Pass
667	Pass	668	Pass	669	Pass	670	Pass
671	Pass	672	Pass	673	Pass	674	Pass
675	Pass	676	Pass	677	Pass	678	Pass
679	Pass	680	Pass	681	Pass	682	Pass
683	Pass	684	Pass	685	Pass	686	Pass
687	Pass	688	Pass	689	Pass	690	Pass
691	Pass	692	Pass	693	Pass	694	Pass
695	Pass	696	Pass	697	Pass	698	Pass
699	Pass	700	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory