



Kanex Fire Solutions Ltd.

Plot No. 7, Paras Industrial Estate, Near Garibsha Pir, Sihor-364240

MANUFACTURER TEST CERTIFICATE

Parameters	Required Specifications (Internal)	Observed	Remarks
Fire Buckets			
Extinguishing Agent	Sand/Water		
Water capacity	9/10 Ltr.		
<u>Dimension Report</u>			
Major Dia. Of bucket	300 mm. (±10)	296 to 298 mm.	Satisfactory
Minor Dia. Of bucket	190 mm. (±10)	190 to 192 mm.	Satisfactory
Total Height of bucket	260 mm. (±10)	265 to 267 mm.	Satisfactory
Sheet thickness of Buckets	0.7 mm.	0.75 to 0.8 mm.	Satisfactory
Weight	1 Kg.	1 to 1.05 kg.	Satisfactory

Materials of Construction: Meets the internal standard requirements.

Painting: Internal part of bucket painted in White & external part with PO/Fire Red color.


Fire Bucket Stand

Stand dimensions, Materials of Construction and Painting meets the Customer requirements.

Painting: Painted with PO/Fire Red color.

Remarks:

Observations made as above for Fire Buckets and stands meets the client requirements.



For Kanex Fire Solutions Ltd.
Aditya Trivedi
(QA-QC & Technical)