

HELIUM LEAK DETECTION TEST

TC No.: HLD/MOD10/CA/HQ/014/25	Model No.: KMCHQ-10-FE36	Date: 10-09-2025
Type and Capacity of Extinguisher	: KMCHQ-10-FE36-Kanex Modular Clean Agent Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCHQ10 014/25	
Batch Quantity	: 20 Nos.	
Serial Numbers	: 00261 To 280	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
261	Pass	262	Pass	263	Pass	264	Pass
265	Pass	266	Pass	267	Pass	268	Pass
269	Pass	270	Pass	271	Pass	272	Pass
273	Pass	274	Pass	275	Pass	276	Pass
277	Pass	278	Pass	279	Pass	280	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory