

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A90/RQ/128/25      | Model No.: KFARQ-6-90%                                          | Date: 16-05-2025 |
| Type and Capacity of Extinguisher | : KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ90%6 128/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 12701 To 12800 And 12705A                                     |                  |
| Month of Manufacturing            | : May/25                                                        |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 12705A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 12701                                                         | Pass   | 12702    | Pass   | 12703    | Pass   | 12704    | Pass   |
| 12705                                                         | Pass   | 12706    | Pass   | 12707    | Pass   | 12708    | Pass   |
| 12709                                                         | Pass   | 12710    | Pass   | 12711    | Pass   | 12712    | Pass   |
| 12713                                                         | Pass   | 12714    | Pass   | 12715    | Pass   | 12716    | Pass   |
| 12717                                                         | Pass   | 12718    | Pass   | 12719    | Pass   | 12720    | Pass   |
| 12721                                                         | Pass   | 12722    | Pass   | 12723    | Pass   | 12724    | Pass   |
| 12725                                                         | Pass   | 12726    | Pass   | 12727    | Pass   | 12728    | Pass   |
| 12729                                                         | Pass   | 12730    | Pass   | 12731    | Pass   | 12732    | Pass   |
| 12733                                                         | Pass   | 12734    | Pass   | 12735    | Pass   | 12736    | Pass   |
| 12737                                                         | Pass   | 12738    | Pass   | 12739    | Pass   | 12740    | Pass   |
| 12741                                                         | Pass   | 12742    | Pass   | 12743    | Pass   | 12744    | Pass   |
| 12745                                                         | Pass   | 12746    | Pass   | 12747    | Pass   | 12748    | Pass   |
| 12749                                                         | Pass   | 12750    | Pass   | 12751    | Pass   | 12752    | Pass   |
| 12753                                                         | Pass   | 12754    | Pass   | 12755    | Pass   | 12756    | Pass   |
| 12757                                                         | Pass   | 12758    | Pass   | 12759    | Pass   | 12760    | Pass   |
| 12761                                                         | Pass   | 12762    | Pass   | 12763    | Pass   | 12764    | Pass   |
| 12765                                                         | Pass   | 12766    | Pass   | 12767    | Pass   | 12768    | Pass   |
| 12769                                                         | Pass   | 12770    | Pass   | 12771    | Pass   | 12772    | Pass   |
| 12773                                                         | Pass   | 12774    | Pass   | 12775    | Pass   | 12776    | Pass   |
| 12777                                                         | Pass   | 12778    | Pass   | 12779    | Pass   | 12780    | Pass   |
| 12781                                                         | Pass   | 12782    | Pass   | 12783    | Pass   | 12784    | Pass   |
| 12785                                                         | Pass   | 12786    | Pass   | 12787    | Pass   | 12788    | Pass   |
| 12789                                                         | Pass   | 12790    | Pass   | 12791    | Pass   | 12792    | Pass   |
| 12793                                                         | Pass   | 12794    | Pass   | 12795    | Pass   | 12796    | Pass   |
| 12797                                                         | Pass   | 12798    | Pass   | 12799    | Pass   | 12800    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**