



Warranty Certificate

Date: 06-11-2025**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** AKG Safety Solutions**Warranty Start Date:** 06-11-2025**Warranty End Date:** 05-11-2030.

This is to certify that the below extinguishers are warranted for a period of 5 year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.	6	As Per Annexure – I
2	KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	5	As Per Annexure – I
3	KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg..	1	As Per Annexure – I
4	KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	2	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. 25-26/M/000439 Dated: 06-11-2025 P.O.No. AKGSS/KFSL/75/25-26 are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**