

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/047/25	Model No.: KMCRQ-5	Date: 24-07-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 047/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 02301 To 2350	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 02301 To 2350 and removed from the Lot/Batch							
2301	Pass	2302	Pass	2303	Pass	2304	Pass
2305	Pass	2306	Pass	2307	Pass	2308	Pass
2309	Pass	2310	Pass	2311	Pass	2312	Pass
2313	Pass	2314	Pass	2315	Pass	2316	Pass
2317	Pass	2318	Pass	2319	Pass	2320	Pass
2321	Pass	2322	Pass	2323	Pass	2324	Pass
2325	Pass	2326	Pass	2327	Pass	2328	Pass
2329	Pass	2330	Pass	2331	Pass	2332	Pass
2333	Pass	2334	Pass	2335	Pass	2336	Pass
2337	Pass	2338	Pass	2339	Pass	2340	Pass
2341	Pass	2342	Pass	2343	Pass	2344	Pass
2345	Pass	2346	Pass	2347	Pass	2348	Pass
2349	Pass	2350	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory