

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/317/25	Model No.: KFARQ-6-50%	Date: 10-10-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 317/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 31601 To 31700 And 31605A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 31605A and removed from the Lot/Batch							
31601	Pass	31602	Pass	31603	Pass	31604	Pass
31605	Pass	31606	Pass	31607	Pass	31608	Pass
31609	Pass	31610	Pass	31611	Pass	31612	Pass
31613	Pass	31614	Pass	31615	Pass	31616	Pass
31617	Pass	31618	Pass	31619	Pass	31620	Pass
31621	Pass	31622	Pass	31623	Pass	31624	Pass
31625	Pass	31626	Pass	31627	Pass	31628	Pass
31629	Pass	31630	Pass	31631	Pass	31632	Pass
31633	Pass	31634	Pass	31635	Pass	31636	Pass
31637	Pass	31638	Pass	31639	Pass	31640	Pass
31641	Pass	31642	Pass	31643	Pass	31644	Pass
31645	Pass	31646	Pass	31647	Pass	31648	Pass
31649	Pass	31650	Pass	31651	Pass	31652	Pass
31653	Pass	31654	Pass	31655	Pass	31656	Pass
31657	Pass	31658	Pass	31659	Pass	31660	Pass
31661	Pass	31662	Pass	31663	Pass	31664	Pass
31665	Pass	31666	Pass	31667	Pass	31668	Pass
31669	Pass	31670	Pass	31671	Pass	31672	Pass
31673	Pass	31674	Pass	31675	Pass	31676	Pass
31677	Pass	31678	Pass	31679	Pass	31680	Pass
31681	Pass	31682	Pass	31683	Pass	31684	Pass
31685	Pass	31686	Pass	31687	Pass	31688	Pass
31689	Pass	31690	Pass	31691	Pass	31692	Pass
31693	Pass	31694	Pass	31695	Pass	31696	Pass
31697	Pass	31698	Pass	31699	Pass	31700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory