

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/258/25	Model No.: KFARQ-6-90%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 258/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 25701 To 25800 And 25705A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25705A and removed from the Lot/Batch							
25701	Pass	25702	Pass	25703	Pass	25704	Pass
25705	Pass	25706	Pass	25707	Pass	25708	Pass
25709	Pass	25710	Pass	25711	Pass	25712	Pass
25713	Pass	25714	Pass	25715	Pass	25716	Pass
25717	Pass	25718	Pass	25719	Pass	25720	Pass
25721	Pass	25722	Pass	25723	Pass	25724	Pass
25725	Pass	25726	Pass	25727	Pass	25728	Pass
25729	Pass	25730	Pass	25731	Pass	25732	Pass
25733	Pass	25734	Pass	25735	Pass	25736	Pass
25737	Pass	25738	Pass	25739	Pass	25740	Pass
25741	Pass	25742	Pass	25743	Pass	25744	Pass
25745	Pass	25746	Pass	25747	Pass	25748	Pass
25749	Pass	25750	Pass	25751	Pass	25752	Pass
25753	Pass	25754	Pass	25755	Pass	25756	Pass
25757	Pass	25758	Pass	25759	Pass	25760	Pass
25761	Pass	25762	Pass	25763	Pass	25764	Pass
25765	Pass	25766	Pass	25767	Pass	25768	Pass
25769	Pass	25770	Pass	25771	Pass	25772	Pass
25773	Pass	25774	Pass	25775	Pass	25776	Pass
25777	Pass	25778	Pass	25779	Pass	25780	Pass
25781	Pass	25782	Pass	25783	Pass	25784	Pass
25785	Pass	25786	Pass	25787	Pass	25788	Pass
25789	Pass	25790	Pass	25791	Pass	25792	Pass
25793	Pass	25794	Pass	25795	Pass	25796	Pass
25797	Pass	25798	Pass	25799	Pass	25800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory