

HYDRO PRESSURE TEST

TC No.: HPT/MOD15/A90/RQ/011/25	Model No.: KMPRQ-15-90%	Date: 14-11-2025
Type and Capacity of Extinguisher	: KMPRQ-15-90%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 15 Kg.	
Batch Number	: KMPRQ90%15 011/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00101 To 110	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00101 To 110 and removed from the Lot/Batch							
101	Pass	102	Pass	103	Pass	104	Pass
105	Pass	106	Pass	107	Pass	108	Pass
109	Pass	110	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory