

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/315/25	Model No.: KFARQ-6-50%	Date: 03-10-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 315/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 31401 To 31500 And 31405A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 31405A and removed from the Lot/Batch							
31401	Pass	31402	Pass	31403	Pass	31404	Pass
31405	Pass	31406	Pass	31407	Pass	31408	Pass
31409	Pass	31410	Pass	31411	Pass	31412	Pass
31413	Pass	31414	Pass	31415	Pass	31416	Pass
31417	Pass	31418	Pass	31419	Pass	31420	Pass
31421	Pass	31422	Pass	31423	Pass	31424	Pass
31425	Pass	31426	Pass	31427	Pass	31428	Pass
31429	Pass	31430	Pass	31431	Pass	31432	Pass
31433	Pass	31434	Pass	31435	Pass	31436	Pass
31437	Pass	31438	Pass	31439	Pass	31440	Pass
31441	Pass	31442	Pass	31443	Pass	31444	Pass
31445	Pass	31446	Pass	31447	Pass	31448	Pass
31449	Pass	31450	Pass	31451	Pass	31452	Pass
31453	Pass	31454	Pass	31455	Pass	31456	Pass
31457	Pass	31458	Pass	31459	Pass	31460	Pass
31461	Pass	31462	Pass	31463	Pass	31464	Pass
31465	Pass	31466	Pass	31467	Pass	31468	Pass
31469	Pass	31470	Pass	31471	Pass	31472	Pass
31473	Pass	31474	Pass	31475	Pass	31476	Pass
31477	Pass	31478	Pass	31479	Pass	31480	Pass
31481	Pass	31482	Pass	31483	Pass	31484	Pass
31485	Pass	31486	Pass	31487	Pass	31488	Pass
31489	Pass	31490	Pass	31491	Pass	31492	Pass
31493	Pass	31494	Pass	31495	Pass	31496	Pass
31497	Pass	31498	Pass	31499	Pass	31500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory