

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/323/25	Model No.: MARQ-6-50%	Date: 15-11-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 323/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 32201 To 32300 And 32205A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 32205A and removed from the Lot/Batch							
32201	Pass	32202	Pass	32203	Pass	32204	Pass
32205	Pass	32206	Pass	32207	Pass	32208	Pass
32209	Pass	32210	Pass	32211	Pass	32212	Pass
32213	Pass	32214	Pass	32215	Pass	32216	Pass
32217	Pass	32218	Pass	32219	Pass	32220	Pass
32221	Pass	32222	Pass	32223	Pass	32224	Pass
32225	Pass	32226	Pass	32227	Pass	32228	Pass
32229	Pass	32230	Pass	32231	Pass	32232	Pass
32233	Pass	32234	Pass	32235	Pass	32236	Pass
32237	Pass	32238	Pass	32239	Pass	32240	Pass
32241	Pass	32242	Pass	32243	Pass	32244	Pass
32245	Pass	32246	Pass	32247	Pass	32248	Pass
32249	Pass	32250	Pass	32251	Pass	32252	Pass
32253	Pass	32254	Pass	32255	Pass	32256	Pass
32257	Pass	32258	Pass	32259	Pass	32260	Pass
32261	Pass	32262	Pass	32263	Pass	32264	Pass
32265	Pass	32266	Pass	32267	Pass	32268	Pass
32269	Pass	32270	Pass	32271	Pass	32272	Pass
32273	Pass	32274	Pass	32275	Pass	32276	Pass
32277	Pass	32278	Pass	32279	Pass	32280	Pass
32281	Pass	32282	Pass	32283	Pass	32284	Pass
32285	Pass	32286	Pass	32287	Pass	32288	Pass
32289	Pass	32290	Pass	32291	Pass	32292	Pass
32293	Pass	32294	Pass	32295	Pass	32296	Pass
32297	Pass	32298	Pass	32299	Pass	32300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory