

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/322/25	Model No.: MARQ-6-50%	Date: 06-11-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 322/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 32101 To 32200 And 32105A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 32105A and removed from the Lot/Batch							
32101	Pass	32102	Pass	32103	Pass	32104	Pass
32105	Pass	32106	Pass	32107	Pass	32108	Pass
32109	Pass	32110	Pass	32111	Pass	32112	Pass
32113	Pass	32114	Pass	32115	Pass	32116	Pass
32117	Pass	32118	Pass	32119	Pass	32120	Pass
32121	Pass	32122	Pass	32123	Pass	32124	Pass
32125	Pass	32126	Pass	32127	Pass	32128	Pass
32129	Pass	32130	Pass	32131	Pass	32132	Pass
32133	Pass	32134	Pass	32135	Pass	32136	Pass
32137	Pass	32138	Pass	32139	Pass	32140	Pass
32141	Pass	32142	Pass	32143	Pass	32144	Pass
32145	Pass	32146	Pass	32147	Pass	32148	Pass
32149	Pass	32150	Pass	32151	Pass	32152	Pass
32153	Pass	32154	Pass	32155	Pass	32156	Pass
32157	Pass	32158	Pass	32159	Pass	32160	Pass
32161	Pass	32162	Pass	32163	Pass	32164	Pass
32165	Pass	32166	Pass	32167	Pass	32168	Pass
32169	Pass	32170	Pass	32171	Pass	32172	Pass
32173	Pass	32174	Pass	32175	Pass	32176	Pass
32177	Pass	32178	Pass	32179	Pass	32180	Pass
32181	Pass	32182	Pass	32183	Pass	32184	Pass
32185	Pass	32186	Pass	32187	Pass	32188	Pass
32189	Pass	32190	Pass	32191	Pass	32192	Pass
32193	Pass	32194	Pass	32195	Pass	32196	Pass
32197	Pass	32198	Pass	32199	Pass	32200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory