

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/084/25	Model No.: KFARQ-4-50%	Date: 13-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 084/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 08301 To 8400 And 8305A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 8305A and removed from the Lot/Batch							
8301	Pass	8302	Pass	8303	Pass	8304	Pass
8305	Pass	8306	Pass	8307	Pass	8308	Pass
8309	Pass	8310	Pass	8311	Pass	8312	Pass
8313	Pass	8314	Pass	8315	Pass	8316	Pass
8317	Pass	8318	Pass	8319	Pass	8320	Pass
8321	Pass	8322	Pass	8323	Pass	8324	Pass
8325	Pass	8326	Pass	8327	Pass	8328	Pass
8329	Pass	8330	Pass	8331	Pass	8332	Pass
8333	Pass	8334	Pass	8335	Pass	8336	Pass
8337	Pass	8338	Pass	8339	Pass	8340	Pass
8341	Pass	8342	Pass	8343	Pass	8344	Pass
8345	Pass	8346	Pass	8347	Pass	8348	Pass
8349	Pass	8350	Pass	8351	Pass	8352	Pass
8353	Pass	8354	Pass	8355	Pass	8356	Pass
8357	Pass	8358	Pass	8359	Pass	8360	Pass
8361	Pass	8362	Pass	8363	Pass	8364	Pass
8365	Pass	8366	Pass	8367	Pass	8368	Pass
8369	Pass	8370	Pass	8371	Pass	8372	Pass
8373	Pass	8374	Pass	8375	Pass	8376	Pass
8377	Pass	8378	Pass	8379	Pass	8380	Pass
8381	Pass	8382	Pass	8383	Pass	8384	Pass
8385	Pass	8386	Pass	8387	Pass	8388	Pass
8389	Pass	8390	Pass	8391	Pass	8392	Pass
8393	Pass	8394	Pass	8395	Pass	8396	Pass
8397	Pass	8398	Pass	8399	Pass	8400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory