

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/316/25	Model No.: KFARQ-6-50%	Date: 03-10-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 316/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 31501 To 31600 And 31505A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 31505A and removed from the Lot/Batch							
31501	Pass	31502	Pass	31503	Pass	31504	Pass
31505	Pass	31506	Pass	31507	Pass	31508	Pass
31509	Pass	31510	Pass	31511	Pass	31512	Pass
31513	Pass	31514	Pass	31515	Pass	31516	Pass
31517	Pass	31518	Pass	31519	Pass	31520	Pass
31521	Pass	31522	Pass	31523	Pass	31524	Pass
31525	Pass	31526	Pass	31527	Pass	31528	Pass
31529	Pass	31530	Pass	31531	Pass	31532	Pass
31533	Pass	31534	Pass	31535	Pass	31536	Pass
31537	Pass	31538	Pass	31539	Pass	31540	Pass
31541	Pass	31542	Pass	31543	Pass	31544	Pass
31545	Pass	31546	Pass	31547	Pass	31548	Pass
31549	Pass	31550	Pass	31551	Pass	31552	Pass
31553	Pass	31554	Pass	31555	Pass	31556	Pass
31557	Pass	31558	Pass	31559	Pass	31560	Pass
31561	Pass	31562	Pass	31563	Pass	31564	Pass
31565	Pass	31566	Pass	31567	Pass	31568	Pass
31569	Pass	31570	Pass	31571	Pass	31572	Pass
31573	Pass	31574	Pass	31575	Pass	31576	Pass
31577	Pass	31578	Pass	31579	Pass	31580	Pass
31581	Pass	31582	Pass	31583	Pass	31584	Pass
31585	Pass	31586	Pass	31587	Pass	31588	Pass
31589	Pass	31590	Pass	31591	Pass	31592	Pass
31593	Pass	31594	Pass	31595	Pass	31596	Pass
31597	Pass	31598	Pass	31599	Pass	31600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory