

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/330/25	Model No.: KFARQ-6-50%	Date: 15-11-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 330/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 32901 To 33000 And 32905A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 32905A and removed from the Lot/Batch							
32901	Pass	32902	Pass	32903	Pass	32904	Pass
32905	Pass	32906	Pass	32907	Pass	32908	Pass
32909	Pass	32910	Pass	32911	Pass	32912	Pass
32913	Pass	32914	Pass	32915	Pass	32916	Pass
32917	Pass	32918	Pass	32919	Pass	32920	Pass
32921	Pass	32922	Pass	32923	Pass	32924	Pass
32925	Pass	32926	Pass	32927	Pass	32928	Pass
32929	Pass	32930	Pass	32931	Pass	32932	Pass
32933	Pass	32934	Pass	32935	Pass	32936	Pass
32937	Pass	32938	Pass	32939	Pass	32940	Pass
32941	Pass	32942	Pass	32943	Pass	32944	Pass
32945	Pass	32946	Pass	32947	Pass	32948	Pass
32949	Pass	32950	Pass	32951	Pass	32952	Pass
32953	Pass	32954	Pass	32955	Pass	32956	Pass
32957	Pass	32958	Pass	32959	Pass	32960	Pass
32961	Pass	32962	Pass	32963	Pass	32964	Pass
32965	Pass	32966	Pass	32967	Pass	32968	Pass
32969	Pass	32970	Pass	32971	Pass	32972	Pass
32973	Pass	32974	Pass	32975	Pass	32976	Pass
32977	Pass	32978	Pass	32979	Pass	32980	Pass
32981	Pass	32982	Pass	32983	Pass	32984	Pass
32985	Pass	32986	Pass	32987	Pass	32988	Pass
32989	Pass	32990	Pass	32991	Pass	32992	Pass
32993	Pass	32994	Pass	32995	Pass	32996	Pass
32997	Pass	32998	Pass	32999	Pass	33000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory