

HYDRO PRESSURE TEST

TC No.: HPT/A9/K/HQ/024/25	Model No.: KFKHQ-9	Date: 17-05-2025
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 024/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00231 To 240	
Month of Manufacturing	: May/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00231 To 240 and removed from the Lot/Batch							
231	Pass	232	Pass	233	Pass	234	Pass
235	Pass	236	Pass	237	Pass	238	Pass
239	Pass	240	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory