

HYDRO PRESSURE TEST

TC No.: HPT/A9/A50/RQ/045/25	Model No.: KFARQ-9-50%	Date: 04-10-2025
Type and Capacity of Extinguisher	: KFARQ-9-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	
Batch Number	: KFARQ50%9 045/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 04401 To 4500 And 4405A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 4405A and removed from the Lot/Batch							
4401	Pass	4402	Pass	4403	Pass	4404	Pass
4405	Pass	4406	Pass	4407	Pass	4408	Pass
4409	Pass	4410	Pass	4411	Pass	4412	Pass
4413	Pass	4414	Pass	4415	Pass	4416	Pass
4417	Pass	4418	Pass	4419	Pass	4420	Pass
4421	Pass	4422	Pass	4423	Pass	4424	Pass
4425	Pass	4426	Pass	4427	Pass	4428	Pass
4429	Pass	4430	Pass	4431	Pass	4432	Pass
4433	Pass	4434	Pass	4435	Pass	4436	Pass
4437	Pass	4438	Pass	4439	Pass	4440	Pass
4441	Pass	4442	Pass	4443	Pass	4444	Pass
4445	Pass	4446	Pass	4447	Pass	4448	Pass
4449	Pass	4450	Pass	4451	Pass	4452	Pass
4453	Pass	4454	Pass	4455	Pass	4456	Pass
4457	Pass	4458	Pass	4459	Pass	4460	Pass
4461	Pass	4462	Pass	4463	Pass	4464	Pass
4465	Pass	4466	Pass	4467	Pass	4468	Pass
4469	Pass	4470	Pass	4471	Pass	4472	Pass
4473	Pass	4474	Pass	4475	Pass	4476	Pass
4477	Pass	4478	Pass	4479	Pass	4480	Pass
4481	Pass	4482	Pass	4483	Pass	4484	Pass
4485	Pass	4486	Pass	4487	Pass	4488	Pass
4489	Pass	4490	Pass	4491	Pass	4492	Pass
4493	Pass	4494	Pass	4495	Pass	4496	Pass
4497	Pass	4498	Pass	4499	Pass	4500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory